

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 238/A.E/P.H.E/Baikunthpur Dated : 20-03-2025

It is certified that an inspection team headed by PRAKHAR BELE (S.D.O.) (Name of Officers with designation) from PUBLIC HEALTH ENGINEERING DEPARTMENT (Name of Department/ Office) inspected the THE NEW DELHI PUBLIC SCHOOL, NARSINGPUR, BAIKUNTHPUR, DISTT. KOREA (CHHATTISGARH) (Name & Address of the school) on 20-03-2025 (date of inspection) and found that the THE NEW DELHI PUBLIC SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of ONE YEAR

Signature with Seal:

Prakhar Bele
Assistant Engineer
P.H.E. Sub Dn. Baikunthpur
Distt. Korea (C.G.)

Name : PRAKHAR BELE

Designation : S.D.O.

Name & Address of the Office / Department :

PUBLIC HEALTH ENGINEERING DEPARTMENT BAIKUNTHUR,

DISTT. KOREA (C.G.)

To

THE NEW DELHI PUBLIC SCHOOL

NARSINGPUR, BAIKUNTHPUR, DISTT. KOREA (CHHATTISGARH)

(Name & Address of the Institution)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

DISTRICT WATER TESTING LABORATORY

(NATIONAL DRINKING WATER MISSION)

P.H.E.D.- KORIYA (C.G.)

BLOCK- Baikunthpur

VILLAGE – Baikunthpur

Details of source and location

1.The New Delhi Public School

Nurshingpur

DISTRICT - Korea

Particulars of sample

(1) Date of Collection - 10-03-2025

(2) Collection by -:

(3) Later No./Date -: Q/10.03.2025

(4) Date of Analysis -: 11-03-2025

(5) Sample ID -:

TESTING REPORT -: Within Permissible Limit.

S.no	Parameters	Units Table	Acceptable	Cause of Rejection	Result					
					1	2	3	4	5	6
1	<u>PHYSICAL</u> Temperature	°C	-	-						
2	Turbidity	N.T.U.	2.5	5.0	0.07	-	-	-	-	-
3	Colour	Pt.Cobalt Scale	5.0	25	7.0	-	-	-	-	-
4	Taste & Odour	-	Unobjectionable	Objectionable	-	-	-	-	-	-
	<u>CHEMICAL</u>				-	-	-	-	-	-
5	PH	PH Scale	7.0 to 8.5	below 7.00 to above 8.5	7.12	-	-	-	-	-
6	Conductivity	Micro Mhos/cm	-	-		-	-	-	-	-
7	Total Alkalinity	mg/l	200	600	25.37	-	-	-	-	-
8	Chlorides	mg/l	200	1000	16.65	-	-	-	-	-
9	Nitrates	mg/l	45	45		-	-	-	-	-
10	Total Hardness as Ca Co3	mg/l	200	600	10.41	-	-	-	-	-
11	Calcium(as Ca)	mg/l	75	200	2.50	-	-	-	-	-
12	Magnessium (as mg)	mg/l	30	150	1.01	-	-	-	-	-
13	Total Disilved Solids	mg/l	500	1500	75	-	-	-	-	-
14	Iron	mg/l	0.1	1.0	0.1	-	-	-	-	-
15	Fluorides	mg/l	1.0	1.5	0.1	-	-	-	-	-
16	Residul Cl	ppm	0.1	0.50	-	-	-	-	-	-
17	Coagulant Dose Jt Test	mg/l	-	-	-	-	-	-	-	-
18	Sulphates	mg/l	200	400	-	-	-	-	-	-
	BACTERIOLOGICAL				-	-	-	-	-	-
19	Coliform Organims 37 °C	MPN/ 100ml/	24 HR 48 HR	-	-	-	-	-	-	-
20	Fecal Coliform	per 100ml	-	-	-	-	-	-	-	-
	SPECIAL TEST				-	-	-	-	-	-
	(i) Arsenic	mg/l	0.05	0.05	-	-	-	-	-	-
	(II)-----	-	-	-	-	-	-	-	-	-

Chemist

District Water Testing Laboratory
P..E.D. KORIYA (C.G.)